

ADDENDUM TO THE BID DOCUMENTS		Page: 1	Total Pages: 1
<u>Addendum No:</u> # 1		<u>Date this Addendum Issued:</u> June 10, 2019	
<u>Issuing Office:</u> Matanuska-Susitna Borough School District (MSBSD) Purchasing Department 690 Cope Industrial Way Palmer, Alaska 99645 Phone: (907) 861-5120 Facsimile: (907) 861-5184		<u>Previous Addenda Issued:</u> None _____ _____ _____ _____	
<u>Return Acknowledgment To:</u> Issuing Department <u>Bid Title:</u> Trapper Creek Elementary School Direct Digital Controls Upgrade <u>Bid No:</u> B19-19		<u>Date and Hour of Bid Due Date:</u> June 19, 2019 at 2:00 P.M. <u>As Advertised (Frontiersman):</u> May 24 and 26, 2019 <u>As Advertised (ADN):</u> May 26 and 27, 2019	
<p>The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence. The bidder must acknowledge receipt of this addendum in the space provided on Appendix #1. Failure to do so may subject the bidder to disqualification.</p> <p>Clarifications:</p> <ol style="list-style-type: none"> 1. Add DDC control points for generator run status as well as general alarm for generator. 2. Add DDC control point for the outside fire water tank. Point will record water temperature. 3. Add run point for Pump 5. This is the pump that supplies water to the fire suppression system from the exterior holding tank. <p>Questions:</p> <ol style="list-style-type: none"> 4. Q: Can sensors be added to the drywall? A: Yes, sensors can be added to drywall. Contractors must use wire mold for exposed areas outside mechanical spaces. <p style="text-align: center;">END OF ADDENDUM #1</p>			

APPROVED BY: _____	Signature on File	DATE: June 10, 2019
--------------------	-------------------	---------------------