

ADDENDUM TO THE BID DOCUMENTS		Page: 1	Total Pages: 3
<u>Addendum No:</u> # 1		<u>Date this Addendum Issued:</u> June 10, 2019	
<u>Issuing Office:</u> Matanuska-Susitna Borough School District (MSBSD) Purchasing Department 690 Cope Industrial Way Palmer, Alaska 99645 Phone: (907) 861-5120 Facsimile: (907) 861-5184		<u>Previous Addenda Issued:</u> None _____ _____ _____ _____ _____	
<u>Return Acknowledgment To:</u> Issuing Department		<u>Date and Hour of Bid Due Date:</u> June 17, 2019 at 2:00 P.M.	
<u>Bid Title:</u> ADA Upgrades for the Matanuska-Susitna Borough School District		<u>As Advertised (Frontiersman):</u> May 22 and 24, 2019	
<u>Bid No:</u> B19-14		<u>As Advertised (ADN):</u> May 21 and 23, 2019	
<p>The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence. The bidder must acknowledge receipt of this addendum in the space provided on Appendix #1. Failure to do so may subject the bidder to disqualification.</p> <p>This addendum incorporates the attached 2 pages.</p> <p>Attachments:</p> <p>Clarifications (2 pages)</p>			
END OF ADDENDUM #1			

APPROVED BY: Signature on File	DATE: June 10, 2019
---	--

ADDENDUM #1

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

Note to Bidders: Bidders are required to acknowledge all addenda on Appendix 1.

The following additions, corrections and changes are hereby made to the above-referenced Invitation to Bid.

CLARIFICATIONS, QUESTIONS AND ANSWERS:

GENERAL QUESTIONS:

1. Q: Is there an engineer's estimate or cost range for this project? Or do you guys not do estimates?

A: The MSBSD does not obtain engineers estimates. The MSBSD expects contractors to submit their best and final pricing.

QUESTIONS FOR GLACIER VIEW SCHOOL:

2. Q: Can the outside push button be relocated?

A: Yes, as long as it complies with door opening times. The MSBSD must approve any relocation before installation begins.

QUESTIONS FOR SUTTON ELEMENTARY SCHOOL:

3. Q: Is an additional piece/ramp needed at the front doors?

A: The MSBSD Facilities Department will complete needed threshold work.

QUESTIONS FOR JOHN SHAW ELEMENTARY SCHOOL:

4. Q: Where curtain walls – how do you want to fish wire? Is surface mounting acceptable?

A: Yes, wire mold surface mounting is acceptable. Submittals must be approved by the MSBSD Facilities Department before work begins.

QUESTIONS FOR MAT-SU CENTRAL SCHOOL:

5. Q: Will Access Control need to be added on the door with a remote release button at reception for Mat-Su Central?

A: Yes, Lenel card reader will need to be added to control access to this door location. Space is available in the site security panel but please provide and install card reader, power supply, and wiring needed to add the reader. Programming will match the programming of the existing Lenel reader at the main front entry.

6. Q: Do you want a Lenel card reader added to the door?

A: Yes, please see answer to question 5.

7. Q: Can it be programmed separately from the front doors?

A: Yes.



8. Q: Do you want a release button added?

A: Yes, please add a release button.

9. Q: Where do you want the release button installed in the front office?

A: Install release button on wall in front office just below the building Lenel main pad and school lockdown button.

QUESTIONS FOR SNOWSHOE ELEMENTARY SCHOOL:

10. Q: Are dual boxes allowed/ok?

A: Yes, due to limited space at this location a dual box push button in the interior vestibule is acceptable.

QUESTIONS FOR KNIK ELEMENTARY SCHOOL:

11. Q: Do you want a dual button in the vestibule?

A: Yes, due to limited space at this location a dual box push button in the interior vestibule is acceptable.

