

ADDENDUM TO THE BID DOCUMENTS	Number of Pages: 1 of 1
<u>Addendum No:</u> # 4	<u>Date this Addendum Issued:</u> December 16, 2016
<u>Issuing Office:</u> Matanuska-Susitna Borough School District (MSBSD) Purchasing Department 690 Cope Industrial Way Palmer, Alaska 99645 Phone: (907) 861-5120 Facsimile: (907) 861-5184	<u>Previous Addenda Issued:</u> <u>1</u> November 28, 2016 <u>2</u> December 5, 2016 <u>3</u> December 13, 2016 _____ _____
<u>Return Acknowledgment To:</u> Issuing Department <u>Bid Title:</u> Testing Services for the Matanuska-Susitna Borough School District <u>Bid No:</u> B17-01	<u>Date and Hour of Bid Due Date:</u> November 30, 2016 at 2:00 p.m. December 7, 2016 at 2:00 p.m. December 14, 2016 at 2:00 p.m. December 20, 2016 at 2:00 p.m. <u>As Advertised (Frontiersman):</u> October 3 and 5, 2016 <u>As Advertised (ADN):</u> October 5 and 7, 2016
The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the Bid Documents. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence.	
<u>NOTE TO BIDDERS: Please sign and return a copy of Addendum #4 with your bid. Failure to do so will be cause for rejection of your bid.</u>	
<i>Method of issuing Addendums: Addendums to this bid will be issued by U.S. Mail and facsimile.</i>	
This addendum is being issued to provide clarification concerning this solicitation.	
QUESTIONS:	
1. We received Addendum# 3 for the above reference bid. For the Fire Alarm testing device counts, there were still several locations that no device counts were given for: Beryozova, Operations and Maintenance, Mat-Su Central School, American Charter, Birchtree Charter, Fronteras Charter, Midnight Sun Charter, Twindly Bridge Charter. Will those device counts be provided prior to the bid date? If not, is it possible to provide previous year's test reports for those buildings?	
<i>Answer: Mat-Su Central, American Charter and Midnight Sun Charter are in leased buildings and no previous reports are available. Birchtree Charter is also in a leased building, but limited information is available: the sprinkler system is wet/dry with 2 wet risers and 1 dry riser. The fire alarm system includes a Simplex 4100U control panel, 10 manual fire alarm boxes, 28 smoke detectors, 2 heat detectors and 36 horn strobes. Fronteras Charter has 6 pull boxes, 2 smoke detectors and 3 heat detectors. Beryozova is comprised of two portables with no sprinkler system. The Operations and Maintenance department does not have a sprinkler system, but the auto shop has an Ansul system. Twiindly Bridge Charter does not have a sprinkler system.</i>	
All other terms and conditions remain the same and unchanged.	
I hereby acknowledge Receipt of Addendum #4:	
_____ Company Name	
_____ Signature	
_____ Printed Name	
_____ Date	
END OF ADDENDUM #4	
APPROVED BY: Signature on File	DATE: December 16, 2016